



the Energy to Lead

CARB Project Seminar ICAT #04-1
Field Demonstration of Prototype Super Boiler
by Dennis Chojnacki, Senior Engineer
Gas Technology Institute

> May 5, 2009


Super Boiler Background

- > U.S. industrial and commercial steam boilers
 - Consume over 6 quads of natural gas per year
 - Wide range of steam uses from process steam to space heating
- > Installed base of steam boilers
 - Largely over 30 years old
 - Average efficiency 76%
 - Typical NOx emissions 85 ppmv
 - Significant potential for improved technology

Project Origin & Goals

- > Super Boiler program
 - Started by DOE and gas industry in 1999
 - GTI team with Cleaver-Brooks selected for project
- > Goals:
 - Maximum efficiency (94 to 95 %)
 - NOx and CO less than 5 ppmv
 - Reduced footprint and weight
 - Cost-effectiveness
- > ICAT Project (Started in July 2005)
 - Select Host Site, Design & Fabricate, Install & Test Two Stage Firetube Super Boiler with TMC HRS

Combustion: two-stage*



- > 80 HP lab boiler
 - Staged burner with internal recirculation
 - Interstage cooling pass
 - No FGR required
 - 3-5 ppmv NO_x at 1-2% O₂



Combustion: two-stage field demo



- > 300 HP field demonstration
 - Clement Pappas & Co.
(Ontario CA)
 - Juice and beverage bottler
 - Steam used for pasteurization and cleaning
 - Steam demand = zero to 9,500 lb/h, highly variable
 - Scale-up included integral head design
 - Operates year-round 24/7
 - Started testing Feb 2008




Combustion: two-stage controls



- > Operator interface via Hawk ICS touchscreen PLC control panel
- > PLC control
 - Critical first stage fuel/air ratio control via fuel delta-P and windbox air delta-P
 - Control implemented via parallel positioning (PP) controllers with VFD trim
 - O₂ trim integrated into air split management
 - Separate setups for heat recovery and bypass modes

Heat Transfer: convective pass



- > Enhanced firetube heat transfer
 - Fire-tubes with extruded aluminum inserts
 - Heat transfer 18X higher than conventional tubes
 - 2-pass boiler can deliver 4-pass performance with a smaller footprint



Heat Transfer: field demonstration



- > 300 HP field demonstration
 - CA demo uses finned firetube inserts in two-pass design
 - Flue gas cooled to 35°F above steam temperature
 - California Super Boiler: 38% lighter & 31% smaller footprint than conventional 300 HP boiler




HEAT RECOVERY

- ❖ Natural gas combustion produces about 18% water from oxidation of H in fuel
- ❖ Water vapor up the stack accounts for 10% of fuel energy input, or 65% of stack loss
- ❖ Key to higher energy efficiency is to recover both sensible *and* latent heat

Heat Recovery: general approach

> Flue gas heat recovery


- Remove sensible heat with two economizers
- Remove latent heat with Transport Membrane Condenser (TMC)
- Suitable for end users with high make-up water usage



Heat Recovery: TMC concept*




- > Transport Membrane Condenser (TMC)
 - Nanoporous ceramic membrane tubes
 - Water vapor permeation via capillary condensation
 - Partial vacuum on shell side
 - Counter-flow configuration



Heat Recovery: expanded system*

> Applications with high condensate return

- Limited make-up water reduces TMC capacity
- Recycle water through humidifying air heater (HAH)



Heat Recovery: TMC hardware

- > Down-flow “Version 1.0”
 - Cylindrical shell design
 - Tube bundles (17” x 4”), 99 tubes/bundle
 - Water on shell side with bottom inlet for natural counter-flow
 - Flue gas cooled to $<160^{\circ}\text{F}$
 - Shell-side vacuum 3 psid
 - Flue gas pressure drop <4 in WC



Heat Recovery: Alabama field demo




SUPER BOILER DEMONSTRATION

Specification Rubber Products, Inc. - Alabaster, Alabama

Last updated at


7/24/2007 10:24:11 AM



Heat Recovery: California field demo




- > Clement Pappas & Co. in Ontario CA
 - Heat recovery system (HRS) similar to Alabama site
 - HRS mounted above boiler




300 hp Super Boiler Clement Pappas Continuous Emission Results

Firing Rate, Stack O₂ and NO_x (corr) vs. Time
March 2, 2009




300 hp Super Boiler NOx Emissions as a function of Firing Rate

Averaged NOx (corr. to 3% O₂) vs. Natural Gas Rate
February 27, 2009



300 hp Super Boiler CP TMC Heat Recovery Results

Firing Rate, TMC and Boiler Stack Flue Gas Temperature vs. Time
March 2, 2009




1st and 2nd Generation Membrane Bundles



Heat Recovery: improved TMC design


- > Up flow “Version 2.0”
 - Modular design
 - 25-HP tube bundle modules
 - Water inside tubes with staged downward flow
 - Above-boiler mounting
 - Easier assembly and service
 - More compact
 - Less ductwork



Proposed Heat Recovery Retrofit for 250 hp 150 psig CB Boiler

>

Schematic



Evaluation of TMC HRS Retrofit to 250 hp Boiler

Present Boiler

- > Fuel: 902,000 therms/yr.
- > Water: 2,000,000 gallons/yr
- > Stack Temperature: 407 F
- > Efficiency: 82 %

Retrofit with TMC HRS

- > Fuel: 786,500 therms/yr
- > Water: 1,600,000 gallons/yr
- > Stack Temperature: 130 F
- > Efficiency: 94 %
- > Savings: 115,500 therms/yr
- > Fuel Savings: \$138,600/yr based on \$1.20/therm
- > Water Savings: \$11,700/yr based on \$2.20/750 gal's

Thanks to the Sponsors of the 300 hp Super Boiler Technology and Field Demo

- > California Air Resource Board
- > U.S. Dept of Energy
- > Southern California Gas Company
- > GTI Sustaining Membership Program
- > Clement Pappas
- > Gas Research Institute
- > Cleaver-Brooks
- > California Energy Com
- > Utilization Technology Development Co.
- > South Coast Air Quality Management District